

Ref. NO.:

202101-0xx-01

Date:

2021-03-10

SEMINAR SCRIPT**Surge Protective Devices (SPDs)**
Technologies – Parameters – Testing

Total pages:	46
Attachments:	0

Content

1	Surge protective devices	6
2	Technologies.....	6
2.1	History.....	6
2.2	Surge Protective Devices (SPDs) versus isolating spark gaps (ISGs)	6
2.3	Classifications	7
2.3.1	Overvoltage response characteristics	7
2.3.1.1	Voltage limiting (clamping)	7
2.3.1.2	Voltage switching (crowbar)	8
2.3.1.2.1	<i>Combination of switching and limiting</i>	9
2.3.2	Occurrence of follow currents.....	9
2.3.3	Leakage current.....	9
2.3.4	End of life behaviour (failure mode).....	10
2.3.4.1	Short circuiting SPDs.....	10
2.3.4.2	Overstressed fault mode for telecom and signalling SPDs.....	10
2.3.5	SPD disconnectors, protection functions and status indicators	12
2.3.5.1	Thermal protection – thermal disconnector	12
2.3.5.2	Leakage current protection.....	12
2.3.5.3	Overcurrent protection.....	12
2.3.6	Means for short circuiting an SPD, protection functions and status indicators	13
2.3.7	Number of ports (terminals) and “feed through” capability	13
2.3.8	Specific classifications for SPDs used in low-voltage power systems	13
2.3.8.1	Discharge capabilities – surge protection versus lightning protection and SPD location	13
2.3.8.1.1	<i>Class I tests – Type 1 (T1) SPDs – SPDs marked “T1”</i>	14
2.3.8.1.2	<i>Class II tests – Type 2 (T2) SPDs – SPDs marked “T3”</i>	14
2.3.8.1.3	<i>Class III tests – Type 3 (T3) SPDs – SPDs marked “T3”</i>	14
2.3.8.1.4	<i>SPDs complying with more than one test class / type designation</i>	14
2.3.8.2	SPDs only for connection between Neutral and Earth (N-PE SPDs).....	15
2.3.9	Specific classifications for SPDs used in telecom and signalling systems.....	15
2.3.9.1	Discharge capabilities – surge protection versus lightning protection and SPD location	15
2.3.9.1.1	<i>SPD category D1 – SPDs marked “D1”</i>	16
2.3.9.1.2	<i>SPD category C2 – SPDs marked “C2”</i>	16
2.3.9.1.3	<i>SPD category C1 – SPDs marked “C1”</i>	16
2.3.9.1.4	<i>SPD category C3 – SPDs marked “C3”</i>	16
2.3.9.2	Current limiting function.....	16
2.4	Specific topologies and designs of SPDs and their characteristics	16

2.4.1	Series combination of switching and limiting components	17
2.4.2	Parallel combination of switching and limiting components	19
2.4.3	Modes of protection and connection types versus configuration	20
2.4.4	Portable SPDs	22
2.4.5	Topologies and designs only used for SPDs for power systems	22
2.4.5.1	Multiple gap constructions	22
2.4.5.2	Triggered gap constructions	23
2.4.6	Topologies and designs only used for SPDs for telecom and signalling systems	24
2.5	Environmental service conditions, mounting and accessibility.....	25
3	Main parameters for SPDs	25
3.1	General parameters for all SPDs.....	25
3.1.1	AC and frequency or DC	25
3.1.2	Continuous operating voltage.....	26
3.1.3	Voltage protection level, limiting voltage, residual voltage	27
3.1.4	Temporary overvoltages – power frequency overvoltages.....	27
3.1.5	Rated load current – rated current.....	28
3.1.6	Total discharge current I_{Total}	28
3.2	Specific parameters for SPDs used in low-voltage power systems	28
3.2.1	Short-circuit current rating I_{SCCR} and follow current interrupt rating I_{fi}	28
3.2.2	Maximum discharge current I_{MAX}	29
3.2.3	Voltage drop for two port SPDs	29
3.2.4	Load-side surge withstand capability for two-port SPDs	29
3.2.5	Voltage rate of rise dU/dt	29
3.2.6	Transition surge current rating for short-circuiting type SPD I_{trans}	29
3.3	Specific parameters for SPDs used in telecom and signalling systems.....	29
3.3.1	Impulse reset time	30
3.3.2	Transmission characteristics	30
3.3.3	Insulation resistance	30
3.3.4	Current response time and current reset time	30
4	Test procedures	31
4.1	Test impulses and impulse generators	31
4.1.1	Impulse waveshapes	31
4.1.1.1	1,2/50 μs voltage impulse.....	31
4.1.1.2	8/20 μs current impulse	32
4.1.1.3	10/350 μs (10/250 μs) lightning impulse current	33
4.1.1.4	Combination wave 1,2/50 μs for voltage and 8/20 μs for current.....	34
4.1.1.5	Other waveforms used for SPDs for telecom and signalling systems only	34
4.1.1.5.1	Combination wave 10/1000 μs for voltage and current	34
4.1.1.5.2	Combination wave 10/700 μs for voltage and 5/320 μs for current	35
4.1.1.5.3	Combination wave 100 V/ μs linear rise for voltage and 10/1000 μs for current	35

4.1.1.5.4	<i>Combination wave 1 kV/μs linear rise for voltage and 10/1000 μs for current</i>	35
4.1.2	Generator topologies and their implication on testing	35
4.1.2.1	Pure voltage impulse generators	35
4.1.2.2	Pure current impulse generators	35
4.1.2.2.1	<i>Direct discharge type</i>	36
4.1.2.2.2	<i>Crowbar type</i>	36
4.1.2.3	Combination wave generators	37
4.2	Coupling of test impulses and decoupling of power supply	38
4.2.1	Coupling of the test impulses to the test sample(s)	38
4.2.2	Decoupling of the test impulses from the power supply (back filters)	38
4.3	Impulse testing and tolerances	38
4.4	Measurement accuracy and measurement uncertainty	39
4.4.1	Voltage probes and their arrangement and attachment	40
4.4.2	Current probes	41
4.5	SPD versus SPD-assembly and mode of protection versus current path	41
4.6	Power supplies	42
4.7	Measured limiting voltage and voltage for clearance determination (U_{max})	43
 LITERATURE		44
General		44
Surge Protective Components, Surge Protective Devices		44
Testing techniques and test equipment		45